CHICAGO ~
<b>FAUCETS</b>
a Geberit company

2100 SOUTH CLEARWATER DRIVE DES PLAINES, ILLINOIS 60018-5999 FITTING NO. 9008


SUBMITTED MODEL NO.

JOB NAME ITEM NO.

SUBMITTED AS SHOWN

SUBMITTED AS NOTED SEE ATTACHED FOR SUBMITTED MODIFICATION NOTES:

- I. ANSI STANDARD SPECIFIES EYEWASH NOZZLES TO BE 33"(838mm) TO 45"(1143mm) ABOVE THE FLOOR.
- \* THESE DIMENSIONS MAY VARY  $\pm 1/4$ " [6.4mm].



## TECHNICAL DATA

- WALL MOUNTED EYE/FACE WASH ROUND II" YELLOW ABS PLASTIC RECEPTOR TWIN FEATHER-FLO ABS PLASTIC EYE/FACE WASH HEADS
- INTEGRAL DUST COVERS FOR SPRAY HEADS THAT RELEASE WHEN VALVE IS ACTIVATED
- FINISH: NO FINISH

- PUSH TO ACTIVE BALL VALVE THAT STAYS OPEN UNTIL MANUALLY CLOSED
- BUILT-IN FLOW CONTROL AND STRAINER HIGH VISIBILITY EMERGENCY SIGN
- MEETS ANSI STANDARD Z358.I

BY: JAR

CHK'D:

APP'D:

DATE: 12-20-04

REV: 08-29-07

9  $\bigcirc$  $\infty$