

Hand-Held Hose Spray w/Dual Sprayhead/ Wall Mount

Model S19-430EFW

Model S19-435EFW

- Complies with American National Standard Z358.1-2004
- Acts as an Eye/Face Wash and Hand-Held Spray
- For Eyes and Face or Body Rinsing
- Wall Bracket Included for Wall Mounting
- Full, One-Year Warranty

Specifications

Quick access emergency eye and face spray features soft flow dual sprayhead for flooding large areas as well as eyes only. Wall bracket included for wall mounting.

UPC and cUPC Approved:

The Emergency Fixtures are certified to comply with the requirements of the Uniform Plumbing Code and the National Plumbing Code of Canada by the International Association of Plumbing and Mechanical Officials (IAPMO).

Construction

8' (2438mm) yellow reinforced thermoplastic hose has 3/8" IPS male thread. Burst strength is 450 PSI.

Standard Equipment

Eye/Face Spray


Perforated sprayheads are ABS plastic and include protective sprayhead covers, feature soft flow dual sprayheads for flooding large areas as well as eyes only. The integral flow assures safe, steady flow under varying water supply conditions.

Valve


Chrome plated brass w/ extended handle stays open once handle is squeezed.

Drench Hose

8' (2438mm) yellow reinforced thermoplastic hose has 3/8" IPS male thread. Burst strength is 450 PSI.



S19-430EFW



S19-435EFW

MODEL	
Model No.	Description
<input type="checkbox"/> S19-430EFW	Hand-Held Hose Spray w/Dual Sprayhead/ Wall Mount
<input type="checkbox"/> S19-435EFW	Hand-Held Hose Spray w/Dual Angled Sprayhead/ Wall Mount

IMPORTANT NOTES:

- Drench hoses must provide a controlled flushing fluid flow that is both tepid and non-injurious to the user per ANSI Z358.1-2004. Refer to ANSI Z358.1-2004 for complete regulatory information regarding the performance, installation, maintenance, and training requirements for drench hoses.
- Installer to supply backflow prevention as required by UPC, IPC and/or local plumbing codes. Contact Bradley or visit www.bradleycorp.com for available options.

Document No. 4780

This information is subject to change without formal notice.
© 2004 Bradley Corporation
10-10-2005 (1 Page Total)

EF4780.1

Bradley

P.O. Box 309, Menomonee Falls, WI 53052-0309
Phone 1-800-BRADLEY FAX 262-251-5817
Web Site: <http://www.bradleycorp.com>