		FITTING NO.
CHICAGO	2100 SOUTH CLEARWATER DRIVE DES PLAINES, ILLINOIS 60018-5999	9000
FAUCETS		SUBMITTED MODEL NO.
a Geberit company		
OB NAME		ITEM NO.
SUBMITTED AS SHOWN		
SUBMITTED AS NOTED		
SEE ATTACHED FOR SUBMITTED MODIFICATION		
1-1/8" 29mm MAX THICKNESS 5-1/2" 140mm  1-1/4" NPS MALE WASTE  DIMENSIONS IN INCHES AND [MILLIMETERS].	S V	PUSH VALVE  7/8" DIA. HOLE 22mm  MOUNTING SCREWS 117mm 6" 152mm  1/2" NPT FEMALE INLET  NTERMEDIATE LINK HOULD BE VERTICAL WHEN ALVE IS IN CLOSED (UP) OSITION AS SHOWN.
TECHNICAL DATA		DATE: 4-16-02
		BY: JAR
- STAINLESS STEEL RECEPTOR - DUAL HIGH IMPACT ABS PLASTIC SPRAY HEADS IN HIGH VISIB		CHK'D:
- RECESSED DECK MOUNTED EYE/FACE WASH - STAINLESS STEEL RECEPTOR - DUAL HIGH IMPACT ABS PLASTIC SPRAY HEADS IN HIGH VISIB - INTEGRAL DUST COVERS FOR SPRAY HEADS THAT RELEASE W - PUSH-TO-ACTIVATE BALL VALVE THAT STAYS OPEN UNTIL MA - HIGH VISIBILITY EMERGENCY SIGN (NOT SHOWN) - MEETS ANSI STANDARD 2358.1	HEN VALVE IS ACTIVATED	2