



NOTES:

1. SPECIFY BURY DEPTH FOR FREEZE RESISTANT VALVE. STANDARD BURY DEPTHS ARE: 24" [610mm], 42" [1067mm] AND 66" [1676mm].
2. WHEN INSTALLING THIS UNIT, LOCAL, STATE OR FEDERAL CODES SHOULD BE ADHERED TO.
3. DIMENSIONS MAY VARY BY $\pm 1/2"$ [12.7mm].

		INFO FAX : 1-888-FAX-HAWS (1-888-329-4297) 1455 Kiappa Ln, Sparks, NV 89431 Phone: 775-359-4712 Fax: 775-359-7424 Haws AG Buchweg 3 CH-3401 Burgdorf Switzerland Haws Mfg. Pte Ltd 74 Sungei Kodat Loop Singapore 729531 e-mail: Haws@hawsco.com website: www.hawsco.com	
		MODEL(S): 8300FP SHOWER EYEWASH COMBO INFO FAX DOC # 2830037 SCALE: 1/32 DRAWING TYPE: INSTALLATION/FAIRBACK	
DES. NO.: EYEWASH DATE: 06/91 CHECKED:	REV. NO.: 002080163.D 09530A00 1/1	DATE: 06/91	SCALE: 1/32