

☐ **G1825HFC** Eyewash, Pedestal Mounted, Hand and Foot Control, Stainless Steel Bowl ☐ G1825P-HFC Eyewash, Pedestal Mounted, Hand and Foot Control, Plastic Bowl

**APPLICATION:** Free standing, pedestal mounted eyewash. Water flow is activated by either flag handle or foot treadle. Two GS-Plus<sup>™</sup> spray heads deliver flood of water for rinsing eyes.

**SPRAY HEAD ASSEMBLY:** Two GS-Plus™ spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from the water flow.

**VALVE:** 1/2" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and Teflon® seals. Valve is activated by flag handle or foot treadle. Unit remains in operation until handle is returned to closed position.

BOWL: 11 1/2" diameter. Bowl is stainless steel (G1825HFC) or orange ABS plastic (G1825P-HFC).

PIPE AND FITTINGS: Schedule 40 galvanized steel. Furnished with orange polyethylene covers for vertical piping for high visibility and corrosion resistance.

**SUPPLY:** 1/2" NPT female inlet. **WASTE:** 1 1/4" NPT female outlet.

**SIGN:** ANSI-compliant identification sign.

**QUALITY ASSURANCE:** Valve, bowl and spray head assembly is factory assembled and water tested prior to shipment.

## **Available Options**

<b>BC</b> Stainless steel bowl cover (G1825HFC only). Cover protects unit against contaminants. Cover is automatically raised when unit is activated.
DC Stainless steel dust cover for each spray head.
HS Auxiliary hand-held drench hose for rinsing eyes, face or body.
SC Self-closing ball valve. Note: Eyewashes with self-closing valves do not comply with ANSI Z358.1 - 2004.
TMV G3600 thermostatic mixing valve precisely blends


hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2004. Refer to "Tempering Units" section for complete technical and product selection



information.



G1825HFC Eyewash, Pedestal Mounted, Hand and Foot Control, Stainless Steel Bowl ☐ G1825P-HFC Eyewash, Pedestal Mounted, Hand and Foot Control, Plastic Bowl



THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL

Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are  $\pm$  1/4" (6mm). rev. 0308

gesafety.com

312 447 8100 TELEPHONE

Sign Included

