

PARTS LISTING **EMERGENCY SHOWER**

(A) ELBOWS

PLASTIC

330-12-08RSE-OR (ORANGE) 330-12-08RSE-GR (GREEN) 330-12-08RSE-YE (YELLOW)

GALVANIZED

300-08SE; 1" IPS STREET ELBOW

STAINLESS STEEL

320-08SE; 1" IPS STREET ELBOW

(B) SHOWER HEADS

PLASTIC

AP450-032ORG (ORANGE) AP450-032GRN (GREEN)


AP450-032YEL (YELLOW)

- STAINLESS STEEL

AP450-048 (10" DIA.) AP450-062 (10" DIA. RECESSED FLANGED)

- CHROME PLATED BRASS AP450-016 (8" DIA.)

HORIZONTAL SHOWERS




(C) VALVE/ARM ASSEMBLIES

- CHROME PLATED BRASS VALVE/STAINLESS STEEL ARM AP600-335H/335V (STAY-OPEN, SINGLE ACTIVATION) AP600-345H/345V (SELF-CLOSING) AP600-340H/340V (STAY-OPEN, DUAL ACTIVATION) RK600-300 (REPAIR KIT FOR AP600-215)

(D) ACTUATING COMPONENTS

AP050-079 (29" STAINLESS STEEL PULL ROD) AP050-079 (29" STAINLESS SIELL PULL ROD)
AP050-080A (47-1/2" STAINLESS STEEL PULL ROD)
AP050-081 (EXTENDED LENGTH STAINLESS STEEL PULL ROD)
AP050-013 (36" SASH CHAIN W/8" DIA. RING)
AP050-018 (DUAL ON/OFF SASH CHAIN)
AP050-016 (102" SASH CHAIN FOR WALL)
AP050-025 (CHROME PLATED CEILING FERRULE) 050-049 (STAINLESS STEEL GUIDE PLATE)

VERTICAL SHOWERS



UNITS (EXCEPT THOSE WITH SELF-CLOSING VALVES) COMPLY WITH THE REQUIREMENTS OF ANSI Z358.1.

TEST ALL EMERGENCY EQUIPMENT AT LEAST WEEKLY.

PL-SHWR Drawing Number:

Approved: _

Revision Number: _

051908-JPP