# **SPEAKMAN®**

## **SE-603-ADA**

SAFE-T-ZONE® EMERGENCY SHOWER AND EYE/FACE WASH

#### **DESCRIPTION**

Floor mounted emergency deluge shower and aerated eye/face wash combination unit. Shower is supplied with a 1" NPTF stay-open full flow ball valve, activated by triangular pull handle. Eye/face wash is supplied with 1/2" NPTF stay-open full flow ball valve, activated by push handle.

#### **SPECIFICATIONS**

Showerhead: 8" Dia. CYCOLAC® Yellow Plastic.

Flow Control: Internal 20 gpm Restrictor.

Valve: 1" NPT Female Brass, Chrome-Plated. Full Flow Stay-Open

Ball Valve.

Activator: Powder Coated Yellow, Aluminum Triangular Pull Rod

Stanchion: 1-1/4" IPS Steel Piping with Brass Fittings.

Inlet & Waste: 1-1/4" NPT Female.

Floor Flange: Brass Casting

Finish: DuraJade™

#### EYE/FACE WASH: SE-400

Bowl: 300 series stainless steel

Spray Heads: (6) brass, chrome-plated aerated Valve: 1/2" NPT female brass, chrome-plated Activator: Stainless steel push handle

Inlet: 1/2" NPT female

Strainer: Brass, chrome-plated, in-line Performance: 9.6 gpm @ 30 psi Compliance: ANSI Z358.1

Universal Emergency Sign Included

Compliance: ANSI Z358.1

Universal Emergency Sign Included

### **OPTIONS**

 $\square$  TS

🖵 ВН	Chrome plated brass showerhead
☐ FLW	Flow switch
☐ FPV	Freeze protection valve
☐ HFO	Hand foot operation
□HS	Hand held spray
<b>□</b> PC	Polished chrome showerhead
□ SPR	Stainless steel pull rod
<b>□</b> SPV	Scald protection valve
☐ SSBV1	1" stainless steel ball valves
☐ SSBV2	<sup>1</sup> / <sub>2</sub> " stainless steel ball valves
□ SSH	Stainless steel showerhead

Top supply

Stay-Open	Q 3/4"		24"		
	(248mm)	<b>—</b> (	610mm)	1	
Pull Rod.					1
	7'-0" TO FLOOR (2134mm)	_			l ∕4″ _ET
		69" MAX		[ <del>]</del> /	<del></del>
	•	TO FLOO	IR 1753mm)		5′-5″ TO FLOOR (165 <sub>,</sub> 1mm)
					ţ
	44" (1118mm)			•	
		ITE: PULL IOWN ROT <i>I</i>			1/4" NPTF STE
			j	∐,/ □ 6″ (	<u>↓</u> 152mm)
Job Name	2				<u>T</u>
Location					

Architect/Engineer \_\_\_\_\_

Sales Representative \_\_\_\_\_

Wholesaler \_\_\_\_\_

Date\_\_\_\_\_ Model #\_\_\_\_