



G1724 v	VideArea™ Eye/Face Wash, Wall Mounted, Stainless Steel Bowl
G1724P	WideArea™ Eye/Face Wash, Wall Mounted, Plastic Bowl



APPLICATION: WideArea[™] eye/face wash for wall mounting. Four GS-Plus[™] spray-type outlet heads deliver a flood of water over a wide area of coverage for complete rinsing of eyes and face.

SPRAY HEAD ASSEMBLY: Four GS-Plus[™] spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from the water flow.

VALVE: 1/2" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and Teflon[®] seals.

BOWL: 11 1/2" diameter. Bowl is stainless steel (G1724) or orange ABS plastic (G1724P).

MOUNTING: Heavy duty cast aluminum wall bracket with corrosion resistant powder coated finish.

SUPPLY: 1/2" NPT female inlet.

WASTE: 1 1/4" NPT female outlet.

SIGN: ANSI-compliant identification sign.

QUALITY ASSURANCE: Unit is completely assembled and water tested prior to shipment.

Available Options

- **DC** Stainless steel dust cover for each spray head.
- HS Auxiliary hand-held drench hose for rinsing eyes, face or body.
- **SC** Self-closing ball valve. *Note: Eye/face washes with self-closing valves do not comply with ANSI Z358.1 2004.*
- **GRN** Green ABS plastic bowl.
- **YEL** Yellow ABS plastic bowl.
- T Chrome plated brass tailpiece and trap with 1 1/2" IPS waste connection.
- **TP** 1 1/2" OD Chrome plated brass tailpiece.
- **TMV** G3600 thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2004. Refer to "Tempering Units" section for complete technical and product selection information.








□ **G1724** WideArea[™] Eye/Face Wash, Wall Mounted, Stainless Steel Bowl

□ **G1724P** WideArea[™] Eye/Face Wash, Wall Mounted, Plastic Bowl



Sign Included



Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are \pm 1/4" (6mm). rev. 0308

THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL

Units have been tested to and comply with ANSI Z358.1 - 2004

