

# \$19-672, \$19-680

## Portable Pressurized Eyewash & Drench Hose Units

- Complies with American National Standard Z358.1-2004 as a supplemental eyewash only
- 5-Gallon Pressurized Tank
- S19-680 Tank is ASME-Rated
- Highly Visible Yellow-Colored Hose Spray
- Universal Identification Sign and Inspection Tag Included
- Full, One-Year Warranty

## **Specifications**

Ideal for providing emergency protection in areas where permanent water supply is not available. Supplements permanent eyewash fixture installations.

### Construction

5-gallon pressure tank is constructed of stainless steel. 25%" (635mm) high and 8%" (216mm) outside diameter. Weighs 14 lbs. empty and 43 lbs. full. S19-680 weighs-27 lbs. empty and 56 lbs. full. Eyewash heads are chrome-plated brass. Tire filler valve with 0–160 PSI air gauge. 8' handheld hose spray has chrome-plated metal parts. Flow from hose maintained approximately 2% minutes. Flow from eyewash approximately 8 minutes. Hose burst strength is 450 PSI.

## Standard Equipment

#### 5-Gallon Tank

Stainless steel pressure tank has built-in carrying handles and resilient bottom. Tire filler valve with 0–160 PSI air gauge. Pressure relief valve prevents accidental over pressurization.

#### Eyewash


Twin chrome-plated brass, soft flow eyewash heads with automatic flow control stay-open valve. Protective dust covers are included. Hand operated by a large, higly visible stainless steel push handle. Flow from eyewash maintained approximately 8 minutes.

#### **Hand-Held Hose Spray**

8' (2438mm) yellow hose spray with hand-held squeeze-type valve, full-size spray nozzle, and hose clamp. All metal parts are chrome-plated. Flow maintained for approximately  $2\frac{1}{2}$  minutes.

Model	Description
□ \$19-672	5-Gal. Portable, Pressurized Unit w/ Eyewash & Drench Hose
□ S19-680	5-Gal. Portable, Pressurized Unit w/ Eyewash & Drench Hose ASME-Rated

**Important Note:** Personal eyewash equipment does not meet the criteria of plumbed or self-contained eyewash equipment. Personal eyewashes support plumbed or self-contained units but shall not replace them.



Emergency Fixtures Document No. 4920 Page 1 of 1
This information is subject to change without formal notice.
4/16/09

© 2009 Bradley Corporation P.O. Box 309, Menomonee Falls, WI 53052-0309 Phone: 800.BRADLEY (800.272.3539) Fax: 262.253.4161 bradleycorp.com