SPEAKMAN COMPANY

SE-626 Installation, Maintenance & Operation Instructions

SAFE-T-ZONE® EMERGENCY SHOWER AND EYEWASH

DESCRIPTION

Floor mounted emergency deluge shower and aerated eyewash combination unit. Shower is supplied with a 1" NPTF stayopen full flow ball valve, activated by triangular pull handle. Eyewash is supplied with 1/2" NPTF stay-open full flow ball valve, activated by push handle.

SPECIFICATIONS

SHOWER HEAD: 8" Dia. Stainless Steel.
FLOW CONTROL: Internal 20 gpm Restrictor.
VALVE: 1" NPT Female Stainless Steel. Full Flow Stay-Open Ball Valve.
ACTIVATOR: Stainless Steel Tube.
STANCHION: 1-1/2" Stainless Steel, 18 Gauge Tubing.
INLET & WASTE: 1-1/4" NPT Male.
FLOOR FLANGE: Stainless Steel With (4) 7/16" Dia. Mounting Holes On 4" Centers.
FINISH: Stainless Steel.
EYE/FACE WASH: SE-582 (Reference additional SE-582 I,M,O sheet)
SHIPPING WEIGHT: 39 lb.
EMERGENCY SIGN: 7-7/8" x 12" Plastic Wall Sign.

OPTIONS

\diamond	AL1 (Air Horn Alarm)	\diamond	XPR (Extended Pull Rod)	\diamond	FPV (Anti-Freeze Protection Valve)
\diamond	AL2 (Electrical Alarm)	\diamond	HS (Hand-held Spray)	\diamond	SPV (Anti-Scald Protection Valve)
\diamond	AL3 (Electrical Alarm)	\diamond	PC (Polished Chrome Shower Head)	\diamond	VPL (Vapor Proof Light)
\diamond	AL2-C1D2 (Electrical Alarm / Haz. Area)	\diamond	BH (Brass Shower Head)	\diamond	HFO (Hand & Foot Operation)
\diamond	AL3-C1D2 (Electrical Alarm / Haz. Area)	\diamond	FLW (Flow Switch)	\diamond	SGN6 (Combination Floor Sign)

INSTALLATION

When assembling use wrench to tighten connection joints. Be sure and use pipe sealant on all threaded connections. Review drawing (as shown on other side) to assure proper location of inlets, outlets, and accessories. The best method to assembling this unit is as follows: (1) Mount the bottom stanchion section to the floor using suitable anchors. Then assemble the middle section and then the top section, making sure rubber sealing gasket is seated correctly. (Use pipe sealant on all joints). (2) Rest the eyewash bowl on the rubber washer and drain spud, making sure to get the bowl as level as possible. (3) Once bowl is positioned correctly on spud, apply plumbers putty to drain strainer and tighten with hex tool (supplied). (3) Take 1/2" stainless steel flexible hose and connect it to the 1/2" NPTM supply outlet located on stanchion and 1/2" in-line strainer on eye/face wash. (4) Assemble pull rod and shower head. (5) Once unit is completely assembled, connect potable water supply to 1-1/4" top inlet, and 1-1/4" waste to bottom outlet. Failure to use potable water can result in emergency units producing impure or contaminated water causing possible further injury. The drain tailpiece or waste should be connected to an adequate drain in compliance with local plumbing codes.

OPERATION

The *shower* is activated by pulling the triangle pull handle. Once the valve is activated the head will continue to discharge water until the valve is manually closed. This is done by pushing up the pull handle to the off position. The *eyewash* is activated by pushing the push handle back 90°. The unit will operate until the push handle is manually pulled back up to the off position.

TESTING PROGRAM

The American National Standards Institute (ANSI) states that all safety emergency equipment shall be activated on a weekly basis to flush the line and verify proper operation. Speakman Company furnishes a testing record tag (91-0635) with each unit. On this tag the date of inspection and the inspector's initials should be noted.


MAINTENANCE

The valve and the eyewash are the only portion of the unit that may require maintenance. Should you need parts to repair this unit, please reference the parts listing below for correct part numbers. Reference additional technical sheets (supplied) for information on the SE-582 eyewash, SE-911-SS valve, and the SE-880 shower head. Before any maintenance is done *be sure to shut the water supply off*.

WARNING: Use only genuine Speakman parts when repairing or replacing components. To order parts call 1-800-537-2107.

SE-626 REPLACEMENT/REPAIR PARTS

ITEM	PART/GROUP #	DESCRIPTION
1	SE-911-SS	1" Ball Valve with Pull Rod
2	SE-880	8" Stainless Steel Shower
		Head
3	G47-0043	Pull Handle
4	SE-582	Eyewash
5	63-0027	S/S Flexible Hose
6	G74-0032-SS	Stanchion Assy.



FLOW DATA

SHOWER:

FLOW PRESSURE PSI (BAR)	30 (2.07)	60 (4.14)
FLOW RATE GPM (LPM)	20 (75)	25 (94)

EYEWASH:

FLOW PRESSURE PSI (BAR)	30 (2.07)
FLOW RATE GPM (LPM)	3.6 (14)

NOTE: This unit should be connected to an uninterrupted source of potable water, with a minimum flowing pressure of 30 PSI and a maximum static pressure of 125 PSI.

Note: All units meet existing ANSI Z358.1 Standards and OSHA Rules. Product improvements may cause specification and dimensional changes without notice.

SPEAKMAN[®]

 PO Box 191
 Wilmington, DE 19899
 Phone: 800-537-2107
 Fax: 800-977-2747
 1/06

 Visit us on the web at www.speakmancompany.com
 92-1594
 Rev-7