CHICACO		FITTING NO.
CHICAGO	2100 SOUTH CLEARWATER DRIVE DES PLAINES, ILLINOIS 60018-5999	9003
FAUCETS		SUBMITTED MODEL NO.
a Geberit company		
IOB NAME	п	TEM NO.
SUBMITTED AS SHOWN		FLANGE MOUNTING
SUBMITTED AS NOTED		SCREW LOCATION
SEE ATTACHED FOR SUBMITTED MODIFICATION	9" DIA. 229mm	2/01/01/4 1/01/55
		3/8" DIA. HOLES (3 PLACES)
* 1	4.2 (0)	EQUALLY SPACED
	4-3/8" 8" DIA B.C. 203mm	r^-
1-3/4" 44mm	111mm 8" MIN. 203mm	-
	STRAINER —	
	1/2" NPT	
* 38-1/2"	FEMALE INLET	
978mm	* 32-1/2"	
	826mm 1-1/4" NPT	
	FEMALE WASTE	
FLOOD		
FLOOR — LINE	* 62/4	
	* 6-3/4" 171mm	
1		* 4 4
* A * * *	* * * *	4 4 4
* THESE DIMENSIO	NS MAY VARY PLUS OR MINUS 1/2" (12.7mm)
DIMENSIONS IN INCHES AND [MILLIMETERS].		
TECHNICAL DATA		DATE: 4-16-02
- FLOOR MOUNTED PEDESTAL EYE/FACE WASH - STAINLESS STEEL RECEPTOR		BY: JAR
- DUAL HIGH IMPACT ABS PLASTIC SPRAY HEADS IN HIGH VISIBILITY YELLOW - INTEGRAL DUST COVERS FOR SPRAY HEADS THAT RELEASE WHEN VALVE IS ACTIVATED - PUSH-TO-ACTIVATE BALL VALVE THAT STAYS OPEN UNTIL MANUALLY CLOSED		CHK'D
- PUSH-TO-ACTIVATE BALL VALVE THAT STAYS OPEN UNTIL - HIGH VISIBILITY EMERGENCY SIGN (NOT SHOWN) - MEETS ANSI STANDARD Z358.1	MANUALLY CLUSED	APP'D
- MICEL'S ANSI STANDARD 2536.1 - FINISH: NO FINISH		REV: A