

T&S BRASS AND BRONZE WORKS, INC. 2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690



Model No.

EC-3100

Sheet: 1 of 2

REG. #A2601 Item No.

T	C 4400 Cimi Vallay CA 900) 402 0450	150 #9001	
This Space for Architect		0-423-0150 Fax: 864-834-3518	www.tsbrass.com	(T.C)
	Date			ChekPoint [™]
	Quantity	ADA Compliant		
	Quantity	ADA Compliant		
			Rigid Goose	eneck
			w/ 2.2 GPM	[8.3 L/min]
Architect/Engineer	2.5/0" × 4.2/40" × 2"	Doon	√Vandal Resi	stant Aerator
	3 5/8" x 4 3/16" x 2" [92mm x 106mm x 5 Waterproof Control N w/ Internal Flow Con AC or DC operated v —24" [610mm] Sensor Cable	1mm] //odule Box (Blue) trol Setting Switches,		11 1/4" [286mm]
5	Removeab Strainer	7 5/16" [185mm]	- 1	4 1/8" [105mm]
DECK				
1/2" NPSM x 1/4" NPS 18" [457mm] Long Fle		2 1/4" Max [57mm] Ø1" [25mm Deck Hole		
St. Steel Hose (1)				Mounting Hole
		100-135 VAC Ada w/ 144" [3658mm] Power Cord. (Remove Rubber I	Long Plugs	Detail Ø1" [25mm]
		on Module and Ca to Connect)	ible	1" [25mm]
Temperature Mixing	vaive	irnished w/ (2)		1
w/ Integral Check Val		8" Compression x 1/2" NP " [457mm] Flex. St. Steel		$\angle \phi$ 5/32" [4mm]
NOTE: Supply Stops	by Others			
Deck Mount Rigid		erator, AC/DC Control	Drawn Check DN DN	Approved JHB
Module with Internal Flow Control Setting Switches, Temperature Control Mixing Valve w/ Integral Check Valves				
		ble Connector Hoses	NTS	10/16/09



T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690



Model No.

Item No.


EC-3100

G. #A2601

Travelers Rest, SC: 800-476-4103 Simi Valley, CA: 800-423-0150 Fax: 864-834-3518 www.tsbrass.com



ITEM	SALES	DESCRIPTION	
NO.	NUMBER		
1	B-0199-06	VR Aerator w/ Key	
2	044A	3/8" to Aerator Adapter	
3	006575-45	-015 O-Ring	
4	017195-45	Angled Sensor w/ Cable	
5	016297-45	Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F	
6	5EF-0006	Mechanical Mixing Valve	
7	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM	
8	Q015425-45	Vandal Resistant Key	
9	016647-45	ChekPoint Module (Blue)	
10	5EF-0002	A/C Transformer	





Flow Control Switches are located inside Module Housing in Black Box next to Battery Compartment.
*Switches are set to DEFAULT position: Auto Time Out = 10 seconds
Shut Off Delay = 1 second
Auto Flush = OFF

Remove (4) screws and back cover to access switches.

*Available Water Flow Control Selections:

(6) Auto Time Out Selections - 10 sec, 25 sec, 45 sec, 60 sec, 3 min, 20 min

(4) Shut Off Delay Selections - 1 sec, 2 sec, 4 sec, 10 sec

Auto Flush for 30 Seconds After Every 12 Inactive Hours - ON or OFF

Product Specifications: Chrome Plated Brass Electronic Faucet:
Deck Mount Rigid Gooseneck w/ VR Aerator, AC/DC Control
Module with Internal Flow Control Setting Switches,
Temperature Control Mixing Valve w/ Integral Check Valves
18" Long Hot & Cold Supply Stop Flexible Connector Hoses

Drawn	Checked	Approved	
DHL	DMH	JHB	
Scale:		Date:	
N	TS	10/16/09	

Sheet: 2 of 2